I am receiving question from city council members about Air Quality issues in their apartments, I assured the concerns that issues are being dealt with, but I need all your air migration reports and abatement reports that will help me ease there minds that everything is taken care of.

Respectfully,

Scott

Scott W Safe | Building Official
Community Development Department
City of Red Wing | www.red-wing.org
419 Bush Street | Red Wing, MN 55066
Tel: 651.385.3611 | Fax: 651.388.9608
Email: scott.safe@ci.red-wing.mn.us

Safe, Scott

From: Ryan Craft <Ryan@frerichsconstruction.com>
Sent: Wednesday, June 11, 2025 7:47 AM
To: Safe, Scott
Subject: RE: Maple Hills
Attachments: as3.pdf; as1.pdf; as5.pdf; as2.pdf; as4.pdf; as6.pdf; as7.pdf; as8.pdf; as9.pdf; as12.pdf; as11.pdf; as10.pdf; as13.pdf; as16.pdf; as15.pdf; as17.pdf; as18.pdf; as19.pdf; as20.pdf; as22.pdf; as21.pdf; as14.pdf; man2.pdf; man1.pdf; man3.pdf

Good morning Scott,

Attached are the air samples that are taken during abatement for the month of April. I have also requested the air samples for the month of May and documentation for any mold remediation that has been completed in any areas that it was encountered. I will forward those along once I received them.

For the air samples the F/FD is in reference to how many fields the Microscopist needs to read to validate the sample. Samples with less than 2,000 liters of air collected need to read extra fields. The F/CC is fibers per cubic centimeter this number is what tells you if you have clean air or not. If the F/CC is greater than .01 then the air would be too "dirty", and we would have to take corrective measures. As you'll see from the sample reports we are well below the actionable levels.

In the meantime, please let me know if there is anything else you need from me.

Thank you,

Ryan Craft
Superintendent

Cell: 612.401.7021 **Office:** 651.787.0687
3600 Labore Road, Suite 8 | Saint Paul, MN 55110
www.frerichsconstruction.com | Think Safety!

FRERICHS CONSTRUCTION

From: Safe, Scott <scott.safe@redwingmn.gov>
Sent: Tuesday, June 10, 2025 3:59 PM
To: Ryan Craft <Ryan@frerichsconstruction.com>
Subject: Maple Hills

CAUTION: This email originated from outside of Frerichs Construction. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Ryan